

City of London



www.buildingenergyquotient.org

Building Energy Quotient ASHRAE's Building Energy Labeling Program



What is Building Energy Labeling?



As the world looks to reduce its energy use, information is the critical first step in making the necessary choices and changes.



Information for Consumers to Allow Educated Choices is Not New


Restaurant Sanitation Ratings



Nutrition Fact Label

Nutrition Facts		
Serving Size 1 cup (120 g)		
Servings Per Container *		
Amount Per Serving		
Calories 80 Calories from Fat 0		
	% Daily Value*	
Total Fat 0g	0%	
Saturated Fat 0g	0%	
Cholesterol 0mg	0%	
Sodium 0mg	0%	
Total Carbohydrate 18g	3%	
Dietary Fiber 5g	20%	
Sugars 9g		
Protein 1g		
Vitamin A 0%	Vitamin C 15%	
Calcium 0%	Iron 0%	
*Percent Daily Values are based on a diet of other people's misdeeds.		
Total Fat	Less Than 65g	90g
Sat Fat	Less Than 20g	25g
Cholesterol	Less Than 300mg	300mg
Sodium	Less Than 2,400mg	2,400mg
Total Carbohydrate	30g	375g
Total Fat	7%	30%

Car Fuel Economy Estimates



A stylized, blue-tinted city skyline with various skyscrapers and buildings, set against a light blue background. The skyline is positioned at the top of the slide, above the main text area.

Building Energy Labels:

- Promote energy efficiency in real estate
- Differentiate efficient buildings in the marketplace (for tenants/buyers)
- Provide feedback on a building's designed and measured energy use
- Identify energy efficiency measures and value in reducing long-term energy costs
- Add to building performance databases



Current Labeling Efforts

- Building certification is becoming widespread
- International efforts:
 - European Union, Singapore and Canada
- U.S. efforts:
 - EPA ENERGY STAR – Portfolio Manager benchmarking
 - DOE Commercial Building Energy Score (pilot phase)
 - USGBC LEED Rating – Broader sustainability rating
 - GBI Green Globes – Broader sustainability rating
 - BOMA 360 – Six O&M focused criteria (incl. energy)
 - State labeling and disclosure programs

A stylized, blue-tinted silhouette of a city skyline with various skyscrapers and buildings, set against a light blue background with a subtle sunburst pattern.

Why ASHRAE? Why now?

- Over 100 years of experience in the building sciences and technology
- Strong technical expertise across all aspects of building design and operation
- Historic focus on developing consensus-based, non-commercial documents
- Respect and credibility within the building community
- Opportunity to support consistent mandatory programs worldwide

ASHRAE's Building EQ

- Voluntary labeling program that draws on successful features of other building labeling & certification programs
- Complements other green building and energy rating/labeling programs
- Provides a way to benchmark performance
- Stimulates adoption of high performance building techniques
- Allows for comparison of As Designed (asset) and In Operation (operational) ratings





How is bEQ Different?

Different from Benchmark programs:

- Greater differentiation for high performing buildings and emphasis on zero net energy
- Expanded building categories covered via a table of median EUI values by climate zone
- Identifies opportunities for improved energy performance (In Operation)
- Consistent process to assess energy performance
- Builds a relationship with an ASHRAE Certified Professional or licensed P.Eng.

A stylized, blue-tinted image of a city skyline with various skyscrapers and buildings, serving as a background for the title.

How is bEQ Different?

Different from Green Building programs:

- Focuses solely on a building's energy use
- Focused on understanding energy use
- Identifies opportunities for improved energy performance (In Operation)
- Allows for comparison between buildings with different operating variables (As Designed)
- bEQ could serve as a consistent energy rating method for both Existing Building and New Construction programs.

A stylized, blue-tinted silhouette of a city skyline with various skyscrapers and buildings. The background is a gradient of light blue and white.

Benefits of bEQ

- Consistent analysis of a building's designed (as built) and actual energy performance
- Recommendations for reducing energy use with rough costs and paybacks
- Potential for continuous improvement in energy efficiency
- Ability to track and show effectiveness of improvements
- Demonstration of corporate responsibility
- Relationship with an ASHRAE certified professional or licensed P.Eng.

bEQ User Feedback

“Thanks to bEQ we were able to investigate the steam consumption data ... and to realize that the EMS was totaling the data wrongly. Without the thorough approach encouraged by bEQ, we would likely not have caught that.”



bEQ User Feedback

“We were also able to identify several operational issues ... that will provide large savings with a very quick payback, and will by themselves pay for several times the cost of the evaluation.”



A stylized, blue-tinted silhouette of a city skyline with various skyscrapers and buildings. The background is a gradient of light blue and yellow.

bEQ Rating Types

In Operation (operational) rating

- Assessment of the building's structure/features and how it is operated
- Based on actual metered energy use of a building
- Applicable for buildings after at least 12-18 months of operation

A stylized, blue-tinted city skyline with various skyscrapers and buildings, set against a light blue background. The skyline is positioned at the top of the slide, above the main title.

bEQ Rating Types

As Designed (asset) rating

- Assessment of the building's physical characteristics and systems
- Independent of a building's occupancy and operating conditions
- Based on results of a standardized energy model as compared to a baseline
- Applicable to both new and existing buildings

bEQ *In Operation* Process

$$(EUI_{\text{measured}} / EUI_{\text{median}}) \times 100$$

- Compares actual metered energy use of candidate building to median/baseline EUI
- Leads to informed energy management decisions
- Provides information on building's IEQ
- Illustrates benefits of equipment and system investments




A stylized, blue-tinted silhouette of a city skyline with various skyscrapers and buildings, set against a light blue background with a subtle sunburst pattern.

bEQ *In Operation* Features

- Includes an ASHRAE Level 1 Energy Audit
- Recommends actions to reduce energy use
- Identifies both peak demand reduction and energy management opportunities
- Recognizes energy use from on-site renewables
- Uses Median EUI's developed from CBECS data, normalized for climate zone and operating hours
- Includes measurement-based IEQ indicators to assure levels of service are maintained

Level 1 Energy Audit



- Preliminary energy-use analysis (PEA) with review of utility bills, rate classes, and peak energy demand
- Space function analysis and energy end use summary
- Identification of low-cost/no-cost energy improvement measures with estimated costs and savings
- Recommended capital improvements with estimated costs and savings

bEQ User Feedback

“The bEQ workbook serves as a good model for information to gather during a Level 1 audit, and also provides a standardized way to present the information.”





bEQ *As Designed* Process

$$(EUI_{\text{standardized}} / EUI_{\text{median}}) \times 100$$

- Compares standardized modeled energy use of candidate building to median/baseline EUI
- Uses specified modeling inputs of building operating parameters
- Uses ENERGY STAR Target Finder to determine median/baseline EUI
- Includes a table of median/baseline EUIs by climate zone for additional building types

A stylized, blue-tinted city skyline with various skyscrapers and buildings, set against a light blue background with a subtle grid pattern.

bEQ *As Designed* Features

- Isolates impact of a building's physical characteristics and systems
- Based on an energy model that normalizes for operational variables using standardized inputs and schedules
- Does not predict actual building energy consumption because operational and occupancy parameters aren't customized to the candidate building


A stylized, semi-transparent blue and yellow city skyline graphic serves as the background for the top portion of the slide. The buildings are rendered in various shades of blue and yellow, creating a modern, urban aesthetic.

Problems with Existing Asset Rating Methodologies

- Results are not comparable among buildings of the same type
- Occupancy parameters not normalized
- Impact of some physical variables neutralized
 - Building Massing
 - Percent of glazing below 40%
- Calculation procedures insufficiently rigorous
- Discrepancies between asset ratings and operational results misunderstood

The bEQ Rating Scale

- The bEQ scale is dimensionless
- Zero point on scale set to “zero net energy”
- Median value (100) set to national median EUI of CBECS for that building type
- Score can go below zero for net energy producing buildings
- Bottom half of scale exceeds 100 for “inefficient” and “unsatisfactory” buildings with high energy usage



The bEQ Rating Scale

Scale Range	Rating	Description
≤ 0	A+	Zero Net Energy
1-25	A	High Performance
26-55	A-	Very Good
56-85	B	Efficient
86-115	C	Average
116-145	D	Inefficient
>145	F	Unsatisfactory

Building Certification Requires Qualified Professionals

- bEQ program requires an ASHRAE certified professional or a P.Eng. licensed in the jurisdiction where the project is located
 - Building Energy Assessment Professional (BEAP) for the In Operation rating.
 - For information: www.ashrae.org/BEAP
 - Building Energy Modeling Professional (BEMP) for As Designed Rating
 - For information: www.ashrae.org/BEMP

Getting Started with a bEQ *In Operation* Rating

www.buildingenergyquotient.org



A stylized, blue-tinted silhouette of a city skyline with various skyscrapers and buildings. The background is a gradient of light blue and yellow.

In Operation Workbook

- Form 1 Building Characteristics
- Form 2 Energy Calculations for Rating
- Form 3 IEQ Screening Information
- Form 4 Energy Savings Suggestions
- Form 5 Energy End-Use Breakdown
- Metered Data Worksheets
- Additional Notes

Getting Started with a bEQ *As Designed* Rating

www.buildingenergyquotient.org



A stylized, blue-tinted city skyline with various skyscrapers and buildings, set against a light blue background with a subtle sunburst pattern.

As Designed Workbooks

- Form 1 Building Characteristics
- Form 2 Energy Calculations for Rating
- Form 3 Candidate Building Modeling Inputs
- Form 4 Energy End Use Breakdown
- Additional Notes
- Standardized Modeling Input Workbook

bEQ Documentation

bEQ Workbook

- Documents Rating Calculation
- Provides Supplemental Information

bEQ Certificate

- Contains Key Building Information
- Satisfies Disclosure Requirements
- Provides Info for Tenants & Governments

bEQ Dashboard

- Illustrates Level of Performance

bEQ Plaque

- Public Display of Building's Rating



bEQ Certificate

Building Energy Quotient Certificate	Building Address:		Building Owner:		Primary Contact for Facility:	
	Building Type:		Year Built:		Gross Floor Area (sq.ft.):	
	Name of certified Building Energy Modeling Professional (BEMP):			Name of certified Building Energy Assessor Professional (BEAP):		
	Part 1 - Building EQ Rating					
	ASHRAE Building Energy Quotient As Designed Rating Rating # = Description Awarded: Month, Yr			ASHRAE Building Energy Quotient In Operation Rating Rating # = Description Awarded: Month, Yr		
	Part 2 – EPA Energy Star Rating for Jurisdictional Compliance					
	EPA ENERGY STAR Target Finder Rating # For the Year of 20-- DATE of ENERGY STAR (SED) Statement of Energy Design Intent:			EPA ENERGY STAR Portfolio Manager Rating # For the Year of 20-- DATE of ENERGY STAR (SEP) Statement of Energy Performance:		
	Part 3 - Building Energy Use Summary					
	Standardized Energy Use		Energy Use Summary (kBtu)		Measured Energy Use	
	Site	Source		Site	Source	
0	0	Natural Gas	0	0		
0	0	Electricity	0	0		
0	0	Fuel Oil	0	0		
0	0	Purchased Steam	0	0		
0	0	Purchased Chilled Water	0	0		
0	0	Other ()	0	0		
0	0	Other ()	0	0		
0	0	Total Energy Use	0	0		
		Qualified				
0	0	Renewable Energy	0	0		
0	0	Renewable % of Total	0	0		
0	0	Net Energy Usage	0	0		
Energy Use Intensity (kBtu/sf-yr)						
Standardized As-Built		Measured				
Site	Source	Site	Source			
0	0	0	0			
Area left blank intentionally Information to be added			Energy Cost Index (\$/sf/yr): NA Electric Load Factor (%): _____ Peak Electricity Demand: kW ___ Month: ___ Electricity Tariff Type: _____ Natural Gas Tariff Type: _____ Other Tariff Type: _____			

Design and Operational Details	Building name:		
	Part 4: Building Energy Design/Operational Features		
	<input type="checkbox"/> Designed to meet minimum state energy code: <input type="checkbox"/> Designed to meet ASHRAE AEDG for building type: <input type="checkbox"/> Designed for USGBC LEED rating. Rating _____ EA Points _____ <input type="checkbox"/> Designed for Green Globes. Rating: _____ <input type="checkbox"/> Designed to Earn the ENERGY STAR <input type="checkbox"/> Designed to meet NBI Core Criteria <input type="checkbox"/> Designed to meet a new construction program (specify) _____		Completed IEQ Measurements for: <input type="checkbox"/> Thermal Comfort <input type="checkbox"/> Lighting Quality <input type="checkbox"/> Indoor Air Quality Design Credentials: <input type="checkbox"/> State Energy Code: _____ <input type="checkbox"/> Other: _____ Operational Credentials: <input type="checkbox"/> Energy Star: Yr _____ Score _____ <input type="checkbox"/> Other: Yr _____ Score _____ <input type="checkbox"/> LEED (version): _____ Yr _____ EA Points _____
	List Top Five Energy Efficiency Design Features: 1. _____ 2. _____ 3. _____ 4. _____ 5. _____		Energy Efficient Improvements since Construction: Item: _____ Date: _____ Item: _____ Date: _____ Item: _____ Date: _____
	<input type="checkbox"/> Design benchmarked to ASHRAE Standard 90.1-20__ following the procedures in Informative Appendix G and achieves a ___% improvement over the baseline.		On Site Renewable Energy Systems: Item: _____ Capacity: _____ Item: _____ Capacity: _____
	Building Subsystem Design Performance Indicators COMcheck Version: _____ Baseline Reference Code: _____		Commissioned Building systems: Item: _____ Date: _____ Item: _____ Date: _____
	<input type="checkbox"/> This building envelope design achieves a ___% improvement over the baseline reference code. <input type="checkbox"/> This building lighting design achieves a ___% improvement over the baseline reference code. <input type="checkbox"/> This building HVAC design achieves a ___% improvement over baseline reference code.		Major Renovations: Item: _____ Date: _____ Item: _____ Date: _____
	<input type="checkbox"/> Design incorporates Submetering		Recommendations for Energy Efficiency Improvements shown in attached list. <input type="checkbox"/> Building includes Submetering
	Building Energy Use by Subsystem End Use		
	Estimated Building Design by Subsystem End Use	kBtu/sf-yr	Measured Energy Use by Subsystem End Use
	Heating		
	Cooling		
	Fans & Pumps		
	Lighting		
	Service Water Heating		
	(Other)		
	(Other)		
0	Total	0	


bEQ Dashboard




Building Energy Quotient Dashboard

EXAMPLE BUILDING
000 MAIN STREET
ANYTOWN, ST 00000

RATED BUILDING TYPE:
BUILDING GROSS SQUARE FOOTAGE:
ORIGINAL CONSTRUCTION DATE:
LATEST MAJOR RENOVATION DATE:



bEQ Plaque



A stylized, blue-tinted silhouette of a city skyline with various skyscrapers and buildings. The background is a gradient of light blue and yellow.

Thank You for Your Attention!

For More Information on bEQ:

www.buildingenergyquotient.org

General questions about bEQ:

info@buildingenergyquotient.org

Technical questions about bEQ:

assessment@buildingenergyquotient.org

A stylized city skyline with various skyscrapers and buildings, rendered in shades of blue and green against a light yellow background.

Questions?



www.buildingenergyquotient.org