



Heating and Cooling

National Sponsor of the CaGBC



# FUEL-SWITCHING HYDRONIC SYSTEMS USING AIR-TO-WATER HEAT PUMPS

**Chris DesRoches, P. Eng.**  
**Applied Product Manager, HVAC Division**  
**Mitsubishi Electric Sales Canada Inc.**

**[chris.desroches@mesca.ca](mailto:chris.desroches@mesca.ca)**

**905-475-3278**

**[www.Climaveneta.ca](http://www.Climaveneta.ca)**

# TOPICS

- **AIR-TO-WATER HEAT PUMP RECAP**
  - TECHNOLOGY OVERVIEW & DESIGN CONSTRAINTS
- **FUEL-SWITCHING HYDRONIC SYSTEMS**
  - ENERGY & GHG EMISSION SAVINGS COMPARISON:
    - ALL-ELECTRIC SYSTEMS VS. BACK-UP NATURAL GAS
    - COST COMPARISON: NATURAL GAS VS. ELECTRIC
- **CENTRAL AIR-TO-WATER HEAT PUMP PLANT SIZING & APPLICATIONS**
  - 2-PIPE CHANGEOVER SYSTEMS
  - HEAT PUMP CASCADE SYSTEMS (2-PIPE)
  - HYBRID 4-PIPE CENTRAL PLANT
  - HEAT RECOVERY
  - HIGH-TEMPERATURE RETROFITS


# LEARNING OBJECTIVES

- **Understand the concept of fuel-switching and its importance for high efficiency retrofit of existing building central plant systems.**
- **Learn design strategies and application techniques of using air-to-water heat pump plant equipment.**
- **Learn about the energy and cost savings, and emission reductions achievable with fuel-switching retrofit of traditional central plant systems with air-to-water heat pumps**




# REVERSIBLE AIR-TO-WATER HEAT PUMP: OPERATING PRINCIPLE


## COOLING MODE



## HEATING MODE




## VAPOR-COMPRESSION REFRIGERATION CYCLE (HEATING MODE)



Coefficient of Performance:

$$COP = \frac{\text{Heat Output } \left( \frac{BTU}{h} \text{ or Watts} \right)}{\text{Power Input (Watts)}}$$

# CENTRAL HYBRID HEAT PUMP PLANT




# AIR-TO-WATER HEAT PUMP: DESIGN CONSIDERATIONS

- UNDERSTAND THE INFLUENCE OF OUTSIDE AIR TEMPERATURE
- DESIGN HYDRONIC SYSTEM BASED ON HEAT PUMP CAPABILITIES INSTEAD OF FITTING INTO EXISTING DESIGN PRACTICES
- **HEAT PUMP PERFORMANCE VARIES WITH OUTSIDE AIR TEMPERATURE:**
  1. SUPPLY TEMPERATURE REDUCTION (OPERATING ENVELOPE)
  2. CAPACITY REDUCTION
  3. COEFFICIENT OF PERFORMANCE REDUCTION

# AIR-TO-WATER HEAT PUMP: OPERATING ENVELOPE

## FULL LOAD HEATING OPERATING LIMITS LEAVING WATER TEMP vs. OUTSIDE AIR TEMP.



London Winter Design Temp.  
(ASHRAE Heating DB 99.6%)

## APPLICATION CONSIDERATIONS:


- Select **LOWEST DESIGN SUPPLY TEMPERATURE** Feasible
- Consider **HIGHER BOILER SUPPLY WATER TEMPERATURE** below ASHP cut-out
- Heat Pump **DESIGN LOAD** vs. **BUILDING HEATING LOAD** at **BIVALENCE** Point

# AIR-TO-WATER HEAT PUMP: SIZING FOR HEATING

## HEATING CAPACITY VS HEATING LOAD

138 kW ATW HP (NOMINAL)

REVERSIBLE UNIT, AIR SOURCE FOR OUTDOOR INSTALLATION



Heat Pump

100%




# AIR-TO-WATER HEAT PUMP: SIZING FOR HEATING

## HEATING CAPACITY VS HEATING LOAD

99 kW ATW HP (NOMINAL)



REVERSIBLE UNIT, AIR SOURCE FOR OUTDOOR INSTALLATION




PRICE

FOOTPRINT

# INFLUENCE OF OUTDOOR AIR TEMPERATURE: COP

## AIR-TO-WATER HEAT PUMP COP VS. OUTSIDE AIR TEMPERATURE & BIN HOURS



# BIN HOUR ANALYSIS FOR LONDON, ON

## AUXILIARY BOILER USAGE HOURS BELOW CUT-OUT FOR VARIOUS SUPPLY WATER TEMPERATURE DESIGN SELECTION POINTS

### Med-High Temp Application

LONDON ON 4-YEAR AVERAGE BIN WEATHER DATA APRIL 2019 - APRIL 2022		
Temperature Range	4-YEAR AVERAGE ANNUAL HOURS	4-YEAR AVERAGE % OF HOURS
T < -5 °C	800	9.1%
-5 °C ≤ T ≤ +10 °C	4,087	46.7%
10 °C < T < 20 °C	2,087	23.8%
20 °C ≤ T	1,786	20.4%

**Total Hours Below -5 °C: 800 Hours**  
 ~ 50 °C @ -5 °C Ambient

### Med Temp Application

LONDON ON 4-YEAR AVERAGE BIN WEATHER DATA APRIL 2019 - APRIL 2022		
Temperature Range	4-YEAR AVERAGE ANNUAL HOURS	4-YEAR AVERAGE % OF HOURS
T < -10 °C	257	2.9%
-10 °C ≤ T ≤ +10 °C	4,630	52.9%
10 °C < T < 20 °C	2,087	23.8%
20 °C ≤ T	1,786	20.4%

**Total Hours Below -5 °C: 257 Hours**  
 ~ 45 °C @ -10 °C Ambient

### Low Temp Application

LONDON ON 4-YEAR AVERAGE BIN WEATHER DATA APRIL 2019 - APRIL 2022		
Temperature Range	4-YEAR AVERAGE ANNUAL HOURS	4-YEAR AVERAGE % OF HOURS
T < -15 °C	73	0.8%
-15 °C ≤ T ≤ +10 °C	4,814	55.0%
10 °C < T < 20 °C	2,087	23.8%
20 °C ≤ T	1,786	20.4%

**Total Hours Below -15 °C: 73 Hours**  
 ~ 35 to 40 °C @ -15 °C Ambient

# CANADA GREEN BUILDING COUNCIL ZERO CARBON BUILDING DESIGN STANDARD v3 (JUNE 2022)



## REQUIREMENTS

### ONSITE COMBUSTION LIMIT FOR SPACE HEATING

Space heating systems should be designed to operate without onsite combustion whenever possible. However, to provide greater design flexibility and recognize current technological and financial barriers, some onsite combustion for space heating is permitted.

Projects must be capable of supplying all space heating with installed non-combustion-based technologies at an outdoor air temperature of  $-10\text{ C}$  or the design temperature, whichever is higher. Space heating technologies whose performance is not directly affected by outdoor air temperature (e.g., ground source heat pumps, electric resistance) must be demonstrated to be able to meet the same fraction of the annual heating demand as an air source heat pump system supported by onsite combustion. at outdoor air temperatures below  $-10\text{ C}$ .

**AUXILIARY COMBUSTION ACCEPTABLE  
PROVIDED THAT A ZERO CARBON TRANSITION  
PLAN ADDRESSES FUTURE ELIMINATION OF  
COMBUSTION BELOW  $-10^{\circ}\text{C}$  LIMIT**



SOURCE: CANADA GREEN BUILDING COUNCIL ZERO CARBON DESIGN STANDARD VERSION 3, PUBLISHED JUNE 2022. AVAILABLE: [CAGBC Zero Carbon Building-Design Standard v3.pdf](#)

# CANADA GREEN BUILDING COUNCIL

## ZERO CARBON BUILDING DESIGN STANDARD v3 (JUNE 2022)

### ZERO CARBON TRANSITION PLAN

ZCB-Design projects that use any onsite combustion for space heating or service hot water, regardless of whether zero emissions biofuels are used, must prepare a Zero Carbon Transition Plan. A Zero Carbon Transition Plan is a costed plan that outlines how a building will adapt over time to remove combustion from building operations. A well-crafted plan will leverage the natural intervention points in a building's capital plan, when retrofits would normally be required. ZCB-Design requires that the transition plan address space heating and service hot water.

---

<sup>21</sup> See Section 3.1.3 of the report, available at, [www.cagbc.org/decarbonize](http://www.cagbc.org/decarbonize).

# CANADA GREEN BUILDING COUNCIL

# ZERO CARBON BUILDING DESIGN STANDARD v3 (JUNE 2022)

## ZERO CARBON TRANSITION PLAN

The Transition Plan must:

- Describe the reasons for onsite combustion and how heating loads have been reduced;
- Describe the mechanical HVAC strategy and how components of the system may be adapted to accommodate non-combustion-based technologies;
- Include measures to facilitate the conversion to non-combustion-based technologies, such as designing the HVAC system to use low-temperature distribution or allocating space for renewable or electrical-sourced heating technologies (e.g., heat pumps);
- Identify and leverage natural intervention points, such as the anticipated end of life of mechanical equipment
- Include a financial comparison of the designed or current systems and an alternative set of non-combustion-based systems;
- Explain the differences between the designed or current systems and the non-combustion-based alternatives in detail, and why the non-combustion-based systems weren't chosen; and,
- Include a 20-year net present value calculation that includes current and projected fuel cost escalation and a three percent discount rate. The [Zero Carbon Building v2 Life Cycle Cost Calculator](#) should be used.<sup>22</sup>

**SOURCE:** CANADA GREEN BUILDING COUNCIL ZERO CARBON DESIGN STANDARD VERSION 3, PUBLISHED JUNE 2022. AVAILABLE: [CAGBC Zero Carbon Building-Design Standard v3.pdf](#)

# HYBRID CENTRAL HEAT PUMP PLANT APPLICATIONS


## AIR-TO-WATER HEAT PUMP APPLICATIONS:

### LOW TEMPERATURE HEATING APPLICATIONS:

- Water-Loop Heat Pump (WLHP)
- Radiant In-Floor Heating
- Domestic Hot Water Preheat
- Winter Ventilation OA Preheat, Summer Reheat for Dehumidification
- Snow Melt (in Heating Mode or during Cooling + Desuperheater)

### MEDIUM TEMPERATURE HEATING APPLICATIONS:

- Terminal Units (Fan Coils, Cabinet Heaters, etc.)
- Central or Zoned AHU Hydronic Heating Coils
- Domestic Hot Water/Preheat



## WATER LOOP HEAT PUMP SYSTEM




Image Source: ASHRAE HANDBOOK: 2020 HVAC SYSTEMS AND EQUIPMENT  
Ch. 9 Fig. 30

# WHY AIR-TO-WATER HEAT PUMPS FOR HYDRONIC SYSTEMS? EMISSIONS COMPARISON


**ONTARIO ELECTRICITY  
GENERATION:  
0.031 kg CO<sub>2</sub>e /kWh**

SOURCE: TAF 2018 AEF:  
[HTTPS://TAF.CA/WP-  
CONTENT/UPLOADS/2019/06/A-  
CLEARER-VIEW-ON-ONTARIOS-  
EMISSIONS-JUNE-2019.PDF](https://taf.ca/wp-content/uploads/2019/06/A-Clearer-View-on-Ontario-Emissions-June-2019.pdf)

**ONTARIO NATURAL GAS  
EMISSION INTENSITY:  
1.888 kg CO<sub>2</sub>e/m<sup>3</sup>  
= 0.18693 kg CO<sub>2</sub>e/kWh**

[1 m<sup>3</sup> Natural Gas = 10.1 kWh]

SOURCE: ONTARIO MINISTRY OF  
ENVIRONMENT AND CLIMATE  
CHANGE'S "GUIDELINE FOR  
QUANTIFICATION, REPORTING AND  
VERIFICATION FOR GHG EMISSIONS -  
JULY 2017", TABLE 400-2






# COP OF VARIOUS HEATING TECHNOLOGIES

## ELECTRIC BOILER


COP = 1



## CONVENTIONAL NATURAL GAS BOILER

COP < 1


VARIES ACCORDING BOILER EFFICIENCY & SYSTEM RETURN TEMP (FOR CONDENSING GAS BOILERS)



## AIR-TO-WATER HEAT PUMP

COP = 2-4+

VARIES ACCORDING TO OUTSIDE AIR TEMP.




1 THERMAL kWh HEATING OUTPUT  
Hot Water For Space Heating & DHW

# CENTRAL PLANT COMPARISON FOR BACK-UP FUEL TYPES

## WHAT DOES YOUR LOW-CARBON ELECTRIFIED SOLUTION LOOK LIKE FOR HYDRONIC SYSTEMS?

### E-BOILER PRIMARY HEAT SOURCE



### 100% ELECTRIC SOLUTION:

- Requires 100% Electric Boiler @ Design Conditions
- Only COP = 1
- Higher Peak Electrical kW (Peak Capacity)
- Backup Generator Sized at Full Electric Boiler kW Load
- Excessive Demand Charges
- Significant Electrical Upgrades for Retrofits
  - Electrical Grids Cannot Support at Scale


# CENTRAL PLANT COMPARISON FOR BACK-UP FUEL TYPES

## WHAT DOES YOUR LOW-CARBON ELECTRIFIED SOLUTION LOOK LIKE FOR HYDRONIC SYSTEMS?

### ATWHP + E-BOILER BACKUP

ELECTRIC  
BACKUP HEAT  
SOURCE

ATW HP  
PRIMARY  
HEAT SOURCE




### AIR-TO-WATER HEAT PUMP + 100% ELECTRIC SOLUTION:

- Cut-out Temperature of ATW Heat Pump Requires **100% Electric Boiler BACKUP** @ Design Conditions (i.e.  $-30^{\circ}\text{C}$ )
- Use Heat Pump For Fuel Switching as Much as Possible to offset
  - Leverage fewer Hours E-Boiler will run (BIN WEATHER)
- Lower kW Input of ATW vs. E-Boiler
  - Backup Capacity still at Peak e-Boiler Peak kW @ COP of 1
- Building Energy Source Fixed to Electric (No Operating Cost Resiliency)

# CENTRAL PLANT COMPARISON FOR BACK-UP FUEL TYPES

## WHAT DOES YOUR LOW-CARBON ELECTRIFIED SOLUTION LOOK LIKE FOR HYDRONIC SYSTEMS?

### ATWHP + NG BOILER BACKUP




### AIR-TO-WATER HEAT PUMP + BACKUP NATURAL GAS

- Cut-out Temperature of ATW Heat Pump Requires **100% Natural Gas Boiler BACKUP** @ Design Conditions
  - **Keep Existing Infrastructure, Extend Existing Boiler Life**
- Use Heat Pump For Fuel Switching as Much as Possible
  - Leverage fewer Hours NG-Boiler will run (BIN WEATHER)
- Significantly Reduced Electric Heat Pump Electrical Power Supply
  - **(2X Less due to COP)**
- **Dual Fuel System Provides Resilience & Redundancy for Operating Costs & Carbon Footprint**
- **No Backup Generator excessive sizing for Electric Boiler @ COP = 1**


# LONDON, ON CENTRAL PLANT HEATING ANALYSIS EXAMPLE: 120 TON CHILLER SYSTEM (2 X 60 TON UNITS)

## FUEL SOURCE COMPARISON: AIR-TO-WATER HEAT PUMP + BACKUP NATURAL GAS OR ELECTRIC

- **500 kW Peak Load** Using TWO 60 Ton Air-to-Water Heat Pump Units
- Comparison for Sizing Based on -10 C and -5 C Cut-out Temperature:
  - 40% Propylene Glycol
  - 45 °C LWT / -10 °C Cut-Out →  $CAP_{RATED} = 135 \text{ kW}$ ;  $COP_{RATED} = 2.07$
  - 50 °C LWT / -5 °C Cut-out →  $CAP_{RATED} = 110 \text{ kW}$ ;  $COP_{RATED} = 2.10$





Peak Load [kW]	Ambient Temp. [°C]	Rated Capacity [kW]	Efficiency COP [W/W]
430	-25	<b>GAS OR ELECTRIC AUX.</b>	
280	-10	135	2.07
230	-5	110	2.10



# CENTRAL PLANT COMPARISON FOR BACK-UP FUEL TYPES


FUEL SOURCE COMPARISON CONSIDERING AIR-TO-WATER HEAT PUMP EFFICIENCIES & BACKUP FUEL USES




# CENTRAL PLANT COMPARISON FOR BACK-UP FUEL TYPES

## FUEL SOURCE COMPARISON CONSIDERING AIR-TO-WATER HEAT PUMP EFFICIENCIES & BACKUP FUEL USES

Central Plant Fuel Source Comparison: 2x NX-N/60 Ton Units




Central Plant Fuel Source Comparison: 2x NX-N/60 Ton Units




Central Plant Back-Up Type

# LONDON, ON CENTRAL PLANT HEATING ANALYSIS EXAMPLE: 120 TON CHILLER SYSTEM (2 X 60 TON UNITS)




### ANNUAL EMISSIONS FUEL SOURCE COMPARISON



Peak Load [kW]	Ambient Temp. [°C]	Rated Capacity [kW]	Efficiency COP [W/W]	Annual Tons CO <sub>2</sub> e Offset (Gas Backup)
420	-23	<b>GAS OR ELECTRIC AUX.</b>		-
280	-10	135	2.07	175.2
230	-5	110	2.10	145.6

### CENTRAL PLANT FUEL SOURCE & BIN HOURS





# REDUCING BUILDING GHG EMISSIONS WITH AIR-TO-WATER HEAT PUMPS


## HOW WILL FOSSIL FUEL PRICES BE AFFECTED IN A LOW-CARBON FUTURE?

### FEDERAL CARBON CHARGE: ONTARIO (ENBRIDGE)

<https://www.enbridgegas.com/Natural-Gas-and-the-Environment/Enbridge-A-Green-Future/Federal-Carbon-Pricing-Program>

2019 – 2022 Federal Carbon Charge Rates for Marketable Natural Gas

Year	\$/ tCO <sub>2</sub> e	cents/m <sup>3</sup>
2019	\$20	3.91
2020	\$30	5.87
2021	\$40	7.83
2022	\$50	9.79



**2023-2030 Will see a rise in Carbon Tax by \$15/Ton CO<sub>2</sub>e, which Translates to ~ 3 ¢ YOY**

\*\*According to the Plan, if implemented, the Carbon tax will increase by \$15/year until it reaches \$170/ton by 2030

1. Source: Ontario Ministry of Environment and Climate Change's "Guideline for Quantification, Reporting and Verification for GHG Emissions - July 2017", Table 400-2
2. Source: National Inventory Report (NRI) 1990-2014: Greenhouse Gas Sources and Sinks in Canada, Part 3

# REDUCING GHG EMISSIONS & OPERATING COSTS WITH AIR-TO-WATER HEAT PUMPS


HOW TO COMPARE 1 kWh<sub>THERMAL</sub> NATURAL GAS TO ELECTRIC HEAT PUMP?

## CONVENTIONAL BOILER

## AIR-TO-WATER HEAT PUMP

Boilers Burn Fossil-Fuels to Heat Water (**NON-Renewable**)

Air-Source Heat Pumps Extract Heat from Environment (**Renewable**)



$$1 \text{ kWh}_{THERMAL,BOILER} = 1 \text{ kWh}_{THERMAL,HEAT PUMP}$$

$$\frac{\$/\text{kWh}_{Natural\ Gas}}{\text{Boiler Efficiency} [\%]} = \frac{\$/\text{kWh}_{Electrical}}{COP}$$

$$\text{Breakeven } COP_{HEAT PUMP} = \frac{\$/\text{kWh}_{Electrical}}{\$/\text{kWh}_{Natural\ Gas}} \times \text{Boiler Efficiency}$$

# REDUCING GHG EMISSIONS & OPERATING COSTS WITH AIR-TO-WATER HEAT PUMPS

## HOW TO COMPARE 1 kWh<sub>THERMAL</sub> PROVIDED BY NATURAL GAS OR HEAT PUMP?


$$COP_{HEAT\ PUMP, Breakeven} = \frac{\$/kWh_{Electrical}}{\$/kWh_{Natural\ Gas}} \times \eta_{Boiler}$$

1 m<sup>3</sup> NG = 10.5 kWh<sub>Natural Gas</sub>

**Average Natural Gas Price**  
 = \$0.40/m<sup>3</sup> Approx. Total Effective Price from TOTAL of NG Bill (Based on 2022 Carbon Pricing @ \$50/Ton CO<sub>2</sub>e)

**Average Electricity Price**  
 = \$0.14/kWh

2022 Cost Ratio ≈ 3.675 E:NG  
 Breakeven COP<sub>95%</sub> = 3.49  
 Breakeven COP<sub>80%</sub> = 2.94




# REDUCING BUILDING GHG EMISSIONS WITH AIR-TO-WATER HEAT PUMPS

## CARBON TAX IMPROVES HEAT PUMP OPERATIONAL COSTS 2022-2030

Year	Electricity Price (\$/kWh)	Natural Gas (\$/m <sup>3</sup> )	Breakeven COP
2022	\$0.140	\$0.40	3.49
2023	\$0.143	\$0.43	3.31
2024	\$0.146	\$0.46	3.16
2025	\$0.149	\$0.49	3.02
2026	\$0.152	\$0.52	2.91
2027	\$0.155	\$0.55	2.80
2028	\$0.158	\$0.58	2.71
2029	\$0.161	\$0.61	2.63
2030	\$0.164	\$0.64	2.56

**1 m<sup>3</sup> = 10.5 kWh<sub>NATURAL GAS</sub>**  
**Boiler Efficiency = 95%**  
**\$0.40/m<sup>3</sup> Natural Gas (2022) + \$0.03**  
**YOY (Carbon Tax Increase)**

**Avg. Electricity \$0.14/kWh (+2% YOY)**




# AIR-TO-WATER CENTRAL PLANT: APPLICATIONS


- **2-PIPE SYSTEMS:**
  - Simple 2-Pipe Change-Over System
  - Cascade Systems
- **4-PIPE HYBRID SYSTEMS** using ATW Heat Pumps
- **PARTIAL HEAT RECOVERY** in 2-Pipe & 4-Pipe Systems (Desuperheater)
- **DOMESTIC HOT WATER**

# CENTRAL HEAT PUMP PLANT: 2-PIPE CHANGEOVER COMMERCIAL SYSTEM


SUMMER COOLING



WINTER HEATING  
AIR-TO-WATER HEAT PUMP




WINTER HEATING  
AUXILIARY BOILER



# FUEL-SWITCH RETROFIT: BIN HOUR ANALYSIS

Air-Cooled Chiller due for Replacement (110 Tons)

Upgrade with Rev. Chiller instead of like-for-like




# FUEL-SWITCH RETROFIT: BIN HOUR ANALYSIS

Air-Cooled Chiller due for Replacement (110 Tons)

Upgrade with Rev. Chiller instead of like-for-like

**118 Tons CO<sub>2</sub>e Offset Annual Compared to NG Boiler operating at same T<sub>SUPPLY</sub>**

Year	Carbon Tax \$/Ton CO <sub>2</sub> e	Annual Savings based on 118 Tons CO <sub>2</sub> e Offset Annually	Cumulative Savings based on 118 Tons CO <sub>2</sub> e Offset Annually
2022	\$ 50	\$ 5,900	\$ 5,900
2023	\$ 65	\$ 7,670	\$ 13,570
2024	\$ 80	\$ 9,440	\$ 23,010
2025	\$ 95	\$ 11,210	\$ 34,220
2026	\$ 110	\$ 12,980	\$ 47,200
2027	\$ 125	\$ 14,750	\$ 61,950
2028	\$ 140	\$ 16,520	\$ 78,470
2029	\$ 155	\$ 18,290	\$ 96,760
2030	\$ 170	\$ 20,060	\$ 116,820






# RETROFIT APPLICATIONS: DECOUPLING GLYCOL




**BUFFER TANK, EXPANSION TANK ON GLYCOL SIDE**

**WATER ONLY ON HX SECONDARY, WATER DISTRIBUTED THROUGH BUILDING**




# TRADITIONAL AIR-COOLED CHILLER ALTERNATIVES

Condensing Unit w/ Evaporator (80 TON)



ATW HP Units  
2x40 Ton  
Sized for Cooling



Heating Boilers  
2x140 kW

**ATW HP ADVANTAGE:**

Heating Selected for:  
50 °C LWT, Rated @ -5 °C OAT = 107.5 kW Each


ASHP HEATING AVAILABLE: 215 kW  
HEATING BOILERS: 280 kW  
UP TO 75% HEATING PROVIDED BY HEAT PUMP

# HYBRID CENTRAL HEAT PUMP PLANT APPLICATIONS

## RETROFIT OR NEW CONSTRUCTION USING WLHP SYSTEM

### WATER-LOOP HEAT PUMP SYSTEM (WLHP):

- Common in MURBs & Office Buildings
- 4-Pipe Comfort Using 2-Pipe System
- Similar  $\Delta T$  for central plant & Terminal Units
- Lower Installation Costs vs. 4-Pipe System
- Heat Recovery During Shoulder Season through Water Loop
- Maximizes Air-to-Water Central Plant Heat Pump Efficiency & Extends Usability of ATW HP down to  $-15^{\circ}\text{C}$ 
  - Backup Natural Gas or Electric Boiler used only below  $-15^{\circ}\text{C}$
  - Provides Redundancy and Back-up to System, Option for Dual Fuel
- Use as Chiller in Cooling mode if Design Permits
  - Cooling Mode as Back-up
  - Apply DHW Preheat in Summer to Maximize ATW HP usage



### AIR-TO-WATER HP CENTRAL PLANT




Image Source: ASHRAE HANDBOOK: 2020 HVAC SYSTEMS AND EQUIPMENT Ch. 9 Fig. 30

# OPTIMIZING ATW HP SELECTION FOR HEATING AND COOLING REQUIREMENT

BEST SIZING METHOD TO ADDRESS IMBALANCE BETWEEN HEATING AND COOLING CAPACITY AT RATED CONDITIONS

**EXAMPLE:**

**WLHP CASCADE SYSTEM**

Summer Cooling: 35 Tons (123 kW) @ 35 °C Ambient

Winter Heating: 378 MBH (110 kW) @ 26 LWT/21 EWT @ -15 °C

## SELECT BASED ON COOLING (35 Tons)

NX-N/452P = 35 Ton Cooling;

Summer Cooling: 35 Tons

Resulting Heating = 238.2 MBH

63% of Requirement only

**Best Value from Investment Point of View**

## SELECT BASED ON HEATING (378 MBH)

NX-N/712P = 450 MBH Heating (120% of Req.)

Summer Cooling: 55 Tons (57% Oversized!)

**Covers more heating load to offset Boiler Usage, but Cooling is grossly oversized**

# ATW HP SIZING OPTIMIZED FOR HEATING REQUIREMENT


BEST SIZING METHOD TO ADDRESS IMBALANCE BETWEEN HEATING AND COOLING CAPACITY AT RATED CONDITIONS

SUMMER COOLING

WINTER HEATING

WINTER HEATING

SUMMER DHW



DHW CHANGEOVER VALVES

HP-2: SIZED FOR MISSING HEATING CAPACITY


USED IN SUMMER FOR DHW HEATING @ HIGHER COP,  $\Delta T$  WITH VALUE ADDED TO DESIGN

# AIR-TO-WATER HEAT PUMP: SIZING FOR HEATING

## HEATING CAPACITY VS HEATING LOAD


138 kW ATW HP (NOMINAL)

REVERSIBLE UNIT, AIR SOURCE FOR OUTDOOR INSTALLATION



# MAXIMIZING ATW HP USAGE FOR DECARBONIZATION: DHW PREHEATING IN SUMMER

**SUMMER:**  
Since ATW HP Not Needed in Summer (Fluid Cooler), put ATW HP to work to supplement DHW Natural Gas Usage with **DHW PREHEAT**



**WINTER:**  
ATW HP Acts as Heat Injector in Winter to serve the WLHP System

# MAXIMIZING ATW HP USAGE FOR DECARBONIZATION: DHW PREHEATING IN SUMMER

WINTER SPACE HEATING DESIGN CONDITIONS VS. SUMMER HEAT PUMP OPERATION:  
65-Ton (225 kW Cooling Cap.) Reversible Heat Pump Chiller (250 kW Heating Capacity at Std. AHRI 550 Conditions)

Design Parameter	Winter Design Conditions	Summer DHW Preheating Performance	
Fluid	40% Propylene Glycol Solution		
Flow Rate [L/s]	7.269		
Service	Space Heating	Summer DHW Preheating	
Ambient Design Temp [°C]	-15	20	30
Design Supply Water Temp [°C]	35	40	40
Temperature Difference $\Delta T$ [°C]	5	12.1	
Capacity @ 100% Load [kW]	139.5	337.6 [+242%]	
COP [W/W]	2.385	4.373 [+183%]	4.532 [+190%]




# AIR-TO-WATER/VRF HYBRID SYSTEM

## LOW-CARBON SOLUTION, LOWER COST COMPARED TO GEOTHERMAL

### ATW HP + WATER-COOLED VRF CENTRAL PLANT BENEFITS:

- Eliminates the “Operating Envelope” Challenge → Perfect comfort at indoor VRF units
- Good Retrofit for Existing Water-Cooled VRF systems to reduce boiler usage
- Supplement with Auxiliary Boiler as Required
  - Replacement: Below  $-15\text{ }^{\circ}\text{C}$  **Bivalence**
  - ATW HP + Boiler **Load Sharing** provides sizing flexibility
- Optimized COP/EER of overall system in both Heating & Cooling






# RETROFIT CHALLENGES: CASCADE SYSTEMS

## VERY-HIGH WATER TEMPERATURE SYSTEMS, FULL DOMESTIC HOT WATER PRODUCTION


### SOLUTION: WATER-WATER HIGH TEMP HEAT PUMP (ENERGY RAISER)

- Retrofit Application to Match Existing System side  $\Delta T$
- Decoupling of glycol via W/W Booster Heat Pump
- Water-Water Heat Pump offers a solution for cascade system to take advantage of ASHP to extreme limits
- ASHP operates at Desired Set Point and constant  $\Delta T$




# 4-PIPE FUEL SWITCH RETROFIT

## WHAT ABOUT 4-PIPE SYSTEMS?




# 2-PIPE AIR-TO-WATER HEAT PUMPS IN 4-PIPE SYSTEMS

Peak Heating & Cooling Load Profiles  
Based on Average Loads at Given Outside Air Temperature  
Toronto, Ontario Example



# 4-PIPE FUEL SWITCH RETROFIT: ENERGY SAVINGS



# 2-PIPE AIR-TO-WATER HEAT PUMPS IN 4-PIPE SYSTEMS


## HEATING & COOLING SIMULTANEOUSLY

### Data Notes:

- Peak Loads shown Reflect Hourly instantaneous peak capacity
- Available Capacities are based on coldest temperature seen during the month for heating, and warmest temperature for cooling
- Where monthly min. Temperature was below -10 °C, available capacity listed is for -10 °C

Building Loads are **DYNAMIC**  
So must be the **Heat Pump System!**

Toronto Monthly Peak Heating & Cooling Loads  
ATW HP Central Plant Available Capacity




# 2-PIPE AIR-TO-WATER HEAT PUMPS IN 4-PIPE SYSTEMS


## HEATING & COOLING SIMULTANEOUSLY

In cases where equipment can not meet heating and cooling loads at the same time, cooling is prioritized, and the auxiliary boiler makes up the missing heating capacity required.

**B** = Load met by Auxiliary Boiler



# PARTIAL HEAT RECOVERY USING DESUPERHEATER 4-PIPE SYSTEMS







# HYBRID 4-PIPE SYSTEM

## FUEL SWITCH RETROFIT: ENERGY SAVINGS

PRE-RETROFIT			
	<i>Vancouver, BC</i>	<i>Toronto, ON</i>	<i>Montreal, QC</i>
<b>Electric Use Intensity</b> [kWh/m <sup>2</sup> ]	174.0	186.8	186.1
<b>Natural Gas Use Intensity</b> [kWh/m <sup>2</sup> ]	196.3	219.1	233.1
<b>Total EUI</b> [kWh/m <sup>2</sup> ]	370.3	405.9	419.2



POST-RETROFIT			
	<i>Vancouver, BC</i>	<i>Toronto, ON</i>	<i>Montreal, QC</i>
<b>Electric Use Intensity</b> [kWh/m <sup>2</sup> ]	191.3	201.0	197.9
<b>Natural Gas Use Intensity</b> [kWh/m <sup>2</sup> ]	89.0	108.8	134.7
<b>Total EUI</b> [kWh/m <sup>2</sup> ]	280.3	309.8	332.6




# 2-PIPE AIR-TO-WATER HEAT PUMPS IN 4-PIPE SYSTEMS HEATING & COOLING SIMULTANEOUSLY

Location	Baseline Emissions [Ton CO <sub>2</sub> e]	Retrofit Emissions [Ton CO <sub>2</sub> e]	Annual Tonnes CO <sub>2</sub> e offset
Vancouver	436.6	210.3	<b>226.3</b>
Toronto	486.5	292.2	<b>194.3</b>
Montreal	516.2	312.4	<b>203.8</b>

Simple Payback – ATW HP vs. Like-for-Like Replacement	
Std. Air-Cooled Chiller \$/Ton	\$ 1,200.00
ATW HP \$/Ton	\$ 2,000.00
Incremental Cost, \$/Ton	\$ 800.00
System Sizing (Tons Nominal)	175
<b>Approximate Incremental Cost over like-for-like replacement</b>	<b>\$ 140,328.00</b>


Gov't of Canada Proposed Plan – December 11 2020



\*\*According to the Plan, if implemented, the Carbon tax will increase by \$15/year until it reaches \$170/ton by 2030

Year	Canadian Federal Carbon Tax* [\$/Ton CO <sub>2</sub> e]	Vancouver		Toronto		Montreal	
		Annual Savings	Cumulative Savings	Annual Savings	Cumulative Savings	Annual Savings	Cumulative Savings
2021	\$ 40	\$ 9,052	\$ 9,052	\$ 7,772	\$ 7,772	\$ 8,152	\$ 8,152
2022	\$ 50	\$ 11,315	\$ 20,367	\$ 9,715	\$ 17,487	\$ 10,190	\$ 18,342
2023	\$ 65	\$ 14,710	\$ 35,077	\$ 12,630	\$ 30,117	\$ 13,247	\$ 31,589
2024	\$ 80	\$ 18,104	\$ 53,181	\$ 15,544	\$ 45,661	\$ 16,304	\$ 47,893
2025	\$ 95	\$ 21,499	\$ 74,679	\$ 18,459	\$ 64,119	\$ 19,361	\$ 67,254
2026	\$ 110	\$ 24,893	\$ 99,572	\$ 21,373	\$ 85,492	\$ 22,418	\$ 89,672
2027	\$ 125	\$ 28,288	\$ 127,860	\$ 24,288	\$ 109,780	\$ 25,475	\$ 115,147
2028	\$ 140	\$ 31,682	\$ 159,542	\$ 27,202	\$ 136,982	\$ 28,532	\$ 143,679
2029	\$ 155	\$ 35,077	\$ 194,618	\$ 30,117	\$ 167,098	\$ 31,589	\$ 175,268
2030	\$ 170	\$ 38,471	\$ 233,089	\$ 33,031	\$ 200,129	\$ 34,646	\$ 209,914


# PARTIAL HEAT RECOVERY (DESUPERHEATER)



The refrigerant circuit is fitted with a **desuperheater** in series with the condenser coils.

Approximately  
**20%**  
of the chiller's capacity<sup>(\*)</sup>


Up to  
**60 °C**  
Leaving Water Temperature




<sup>(\*)</sup> The heat recovery and its amount depend on the unit's operating conditions, in particular the outdoor air temperature and the load percentage.

# PARTIAL HEAT RECOVERY USING DESUPERHEATER

## HEAT RECOVERY TO DOMESTIC HOT WATER SYSTEM (2-PIPE SYSTEM)




## HEAT RECOVERY TO BOILER PRE-HEAT (4-PIPE SYSTEM)



# DOMESTIC HOT WATER PRODUCTION

## DOMESTIC HOT WATER USING INDIRECT STORAGE TANK + SUPPLEMENTAL BOILER



After 50% Draw  
from DHW Tank:

$$T_{\text{TANK}} = \sim 35 \text{ °C}$$

Can Add Heat to DHW  
with ~ 40 °C LWT. Can  
Use HP down to ~ -12 °  
OAT


After 25% Draw  
from DHW Tank:

$$T_{\text{TANK}} = \sim 47.5 \text{ °C}$$

Can Add Heat to DHW  
with ~ 52 °C LWT. Can  
Use HP down to ~ -3 °C  
OAT only


### ATW HP for DHW Application:

- Reduce Boiler work via Heat Pump
- Ability of Heat Pump to Add Heat to DHW tank is a function of DHW Tank Temp and Max LWT available from ATWHP according to OAT



# DOMESTIC HOT WATER PRODUCTION

## DOMESTIC HOT WATER USING INDIRECT STORAGE TANK FOR PREHEATING DHW



## DHW PREHEAT BENEFITS

- Reduce Boiler work via Heat Pump
- Preheat Configuration allows the heat pump to add more heat, more often to the DHW system by operating at a lower temperature. Overall offsets more GHG Emissions
- Secondary DHW Tank, boiler then does a lower temperature lift

## Looking at the PREHEAT Tank:

After 50% Draw  
from DHW  
Preheat Tank:  
 $T_{TANK} = \sim 20^{\circ}\text{C}$




Can Add Heat to DHW  
Preheat with  $\sim 25^{\circ}\text{C}$   
LWT. Can Use HP down  
to  $\sim -15^{\circ}\text{OAT}$

After 25% Draw  
from DHW Tank:  
 $T_{TANK} = \sim 24.5^{\circ}\text{C}$




Can Add Heat to DHW  
with  $\sim 30^{\circ}\text{C}$  LWT. Can  
Use HP down to  $\sim -15^{\circ}\text{C}$   
OAT always



# DESIGN CONSIDERATION: AUXILIARY HEAT

## NX-N-G02-U 152P-812P AUXILIARY HEATING IN SERIES:








# SUMMARY

- **HOLISTIC APPROACH TO MECHANICAL DESIGN IS REQUIRED TO MEET GHG REDUCTION TARGETS**
  - “ONE-SIZE-FITS-ALL” IS NOT ALWAYS COMPATIBLE WITH LOW CARBON
  - SIGNIFICANT SAVINGS CAN BE ACHIEVED WHILE USING CURRENT ATW TECHNOLOGY WITHIN LIMITATIONS
  - REDUCED OPERATING TEMP = INCREASED EFFICIENCY + FACILITATED INTEGRATION
- **INCORPORATING OTHER MEASURES (ENVELOPE UPGRADE) ARE EQUALLY IMPORTANT**
  - LESS HEAT LOSS = REDUCED RETROFIT EQUIPMENT SIZING
  - REDUCED POWER REQUIREMENT FOR ELECTRIFIED HEATING RETROFITS
- **DUAL FUEL PROVIDES BUILDING RESILIENCY**
  - LEVERAGE EXISTING NATURAL GAS INFRASTRUCTURE WHERE IT MAKES SENSE
  - FLEXIBILITY TO MANAGE CARBON FOOTPRINT OR OPERATING COST VIA ENERGY MANAGEMENT STRATEGY
  - TRANSITION TO LOWER EMISSION NATURAL GAS WITH RNG OVER TIME
  - FUTURE PROOFED BUILDING: ATW HP TECHNOLOGY IMPROVEMENT AT END OF LIFECYCLE
  - ELECTRICAL GRID CAPACITY MANAGEMENT
- **TRANSFORMATION OF FINANCIAL/BUSINESS CASE TO SUPPORT LOW-CARBON TRANSITION**
  - OPERATING OR FIRST COST IS NO LONGER THE GOVERNING CRITERIA
  - RETROFIT CODE & TARGETS WILL ACCELERATE ADOPTION
  - FINANCIAL SUPPORT FOR PRIVATE SECTOR + FUEL SWITCHING PROJECT SUPPORT WILL LAUNCH ATW INTO MAINSTREAM

# QUESTIONS?



**mitsubishi  
ELECTRIC**

*Changes for the Better*

**Connect for Design, Selection & Sizing  
Support for your next Project!**

**Chris DesRoches, P. Eng.  
Applied Product Manager, HVAC Division**

**[Email: chris.desroches@mesca.ca](mailto:chris.desroches@mesca.ca)**

**Phone: 905-475-3278**

**[www.Climaveneta.ca](http://www.Climaveneta.ca)**